



175G5245

MCD202022T6CV1

MCD202022T6CV1
 VLT® Compact Starter MCD 202
 22 kW 48A:4-6: 354
 Three phase, 200-575 VAC
 Control voltage: 24 VAC/VDC
 (A) A-Frame

Model code: MCD202022T6CV1

VLT® Compact Starter MCD 200 from Danfoss includes two families of soft starters in the power range 7.5–110 kW.

The series offers easy DIN rail mounting for sizes up to 30 kW, 2-wire or 3-wire start/stop control and excellent starting duty (4 x Ie for 6 seconds).

Heavy starting rating at 4x Ie for 20 seconds.
 Compatible with grounded delta power systems.

PRODUCT DETAILS

Gross weight		2.9 Kilogram	
Net weight		2.4 Kilogram	
Volume		12.896 Liter	
EAN		5702427098848	
Product View (Switch)	GLBL	Global (Standard)	
Product Group	MCD	VLT® Soft Starter MCD	
MCD Series	202	202	MCD 202 soft starters provide Current Limit starting control, TVR soft stop and include a range of motor protection functions
Power Rating	022	22 kW 48A:4-6: 354	
Phase	T	Three phase	
Mains Voltage	6	200-575 VAC	+10% / -15%
Control Supply Voltage	CV1	24 VAC/VDC	± 20%
Frame Size	A	(A) A-Frame	Dimensions (mm) H: 203, W: 98, D:165
Typecode Part 1		MCD202022T6CV1	
Product Catalog	NO_VIEW	NO VIEW	
Variant condition (ref. YV00)		09854 6 MCD202 MCD202022T6CV1 SOFT_202 VLT	
Variant condition (Purch)		09854 6 MCD202 MCD202022T6CV1 SOFT_202 VLT	

Danfoss can accept no responsibility for possible errors in catalogs, brochures and other printed material. Danfoss reserves the right to alter its products without notice. This also applies to products already on order provided that such alterations can be made without sub-sequential changes being necessary in specifications already agreed. All trademarks in this material are property of the respective companies. Danfoss and the Danfoss logotype are trademarks of Danfoss A/S. All rights reserved.

PRODUCT DETAILS

STAT NO	09854	
Modelcode01	MCD202022T6CV1	
ECCN EU	Y901	Y901
ECCN US	EAR99	EAR99
Calculated Gross Weight [kg]	2.9	
Calculated Package Weight	0.5	
Calculated Net Weight [kg]	2.4	
Vendor	ERR01	Cannot Determine Vendor
Recommended Factory	ERR01	Cannot Determine Vendor
Recommended Plant	ERR01	ERR01

For Documents, Software, Visuals and more information, please use this link to visit the product page on Danfoss Product Store [🔗](#)

Accessories

**175G9009** [🔗](#)**USB Module**

USB module for MCD 200 and MCD 500

**175G9004** [🔗](#)**Remote Operator kit MCD200**

Remote control unit for MCD 200 soft starter.

**175G9002** [🔗](#)**Devicenet module, MCD200, MCD500****175G9001** [🔗](#)**Profibus Module, MCD200, MCD500**

Profibus option for MCD 200 and MCD 500

**175G9000** [🔗](#)**Modbus RTU Module, MCD200, MCD500**

Modbus RTU module (RS485) for MCD 200 and MCD 500

**175G9905** [🔗](#)**Profinet module, MCD200, MCD500**

ProfiNet module

For more information, please use this link to visit the product page on Danfoss Product Store [🔗](#)

Danfoss can accept no responsibility for possible errors in catalogs, brochures and other printed material. Danfoss reserves the right to alter its products without notice. This also applies to products already on order provided that such alterations can be made without sub-sequential changes being necessary in specifications already agreed. All trademarks in this material are property of the respective companies. Danfoss and the Danfoss logotype are trademarks of Danfoss A/S. All rights reserved.