








## 61F-LS-CP11-NE

Floatless level switch, plug-in, adjustable sensitivity, one level, 100-240 VAC

# Specifications

Application	Ordinary purified water, Sewage water
Functions	Conductive level control
Installation type	Socket
Terminal type	Plug-in
Size	41 mm
Supply voltage AC	100-240 V
Output type	Relay
Contact description	2 x SPDT
Body color	Black
Number of inputs for electrodes	3

## Accessories

	<b>BF-1</b>	Electrode holder, 1-pole electrode, standard type (150°C), liquid with low specific resistance
	<b>BF-3</b>	Electrode holder, 3 way, standard type (150°C)
	<b>BF-5</b>	Electrode holder, 5 way, standard type (150°C)
	<b>BS-1</b>	Electrode holder, 1-pol electrode, for high pressure or high temperature applications (250°C), 1.96Mpa
	<b>F03-11 PROTECTIVE COVER FOR BF</b>	Protective cover for electrode holders PS or BF series)



**F03-12 FRAME FOR  
FIXATION**

PS Electrode Holder Mounting Plate



**F03-14 1P SEPARATOR**

Electrode separator, 1 electrode, ceramic, 250 °C max, 15 g



**F03-14 3P SEPARATOR**

Electrode separator, 3 electrodes, ceramic, 250 °C max, 30 g



**F03-14 5P SEPARATOR**

Electrode separator, 5 electrodes, ceramic, 250 °C max, 30 g

**F03-60 SUS316  
ELECTRODE SET**

Set including F03-01 SUS316 electrode, F03-02 SUS316 connecting nuts, F03-03 SUS316 lock nuts

**PH-2 HAIPREN CODE 20M**

Underwater Electrode, Hypalon cable, double pole, 20 m length



**PS-31 SUS304 1000MM**

Electrode set, holder & electrodes, 1 m length, 4 mm diameter, non-extendable



**PS-31 SUS304 300MM**

Electrode set, holder & electrodes, 0.3 m length, 4 mm diameter, non-extendable



**PS-3S**

Electrode holder, 3 way



**PS-4S**

Electrode holder, 4 way



**PS-5S**

Electrode holder, 5 way

# Related products



## PF

PF is the MKS relays family sockets range, also suitable for SSR and monitoring products.

# Downloads



## 61F-LS Floatless Level Switch Datasheet

EN PDF 3.01 MB



## Device Selection Guide for Water Level Control Applications Selection Guide

EN PDF 2.84 MB



## EAC Mark removal Discontinuation Notice

EN PDF 221 KB