



CONT. RELAY 62 E DIN EN 50011 6NO+2NC,  
SCREW CONNECTION ALT. CURRENT ACTUATING

**General details:**

<b>Size of the contactor</b>		0
<b>Ambient temperature</b>		
• during operating	°C	-25 ... +55
<b>Protection class IP / on the front</b>		IP20
<b>Reference code</b>		
• according to DIN 40719 extended according to IEC 204-2 / according to IEC 750		K
• according to DIN EN 61346-2		K
• according to DIN EN 81346-2		K

**Control circuit:**

<b>Voltage type / of control feed voltage</b>		AC
<b>Control supply voltage frequency</b>		
• 1	Hz	50
• 2	Hz	60
<b>Control supply voltage</b>		
• at 50 Hz / at AC / rated value	V	220
• at 60 Hz / at AC / rated value	V	264

**Auxiliary circuit:**

<b>Operating current / at AC-15</b>		
• at 230 V / rated value	A	10
• at 400 V / rated value	A	6
<b>Identification number and letter for switching elements</b>		62 E
<b>Number of NC contacts / for auxiliary contacts</b>		2
• lagging switching		0
• delayed switching		0
• asynchronous switching		0
<b>Number of NO contacts / for auxiliary contacts</b>		6
• leading switching		0
• delayed switching		0
• asynchronous switching		0
<b>Number of changeover contacts / for auxiliary contacts</b>		0

### Connection type:

**Design of the electrical connection / for auxiliary and control current circuit**

screw-type terminals

### Mechanical design:

**Mounting type**

screw and snap-on mounting onto 35 mm standard mounting rail according to DIN EN 50022

**Width**

mm 45

**Height**

mm 78

**Depth**

mm 102

### Certificates/approvals:

General Product Approval

Functional Safety / Safety of Machinery



CCC



CSA



UL

[Type Examination](#)

Test Certificates

[other](#)

[Special Test Certificate](#)

[Type Test Certificates/Test Report](#)

Shipping Approval



DNV



GL



LRS



RMRS

other

[Declaration of Conformity](#)

[other](#)

[Environmental Confirmations](#)

### Safety:

<b>Protection against electrical shock</b>		finger-safe
<b>B10 value / with high demand rate</b> <ul style="list-style-type: none"> <li>• according to SN 31920</li> <li>• note</li> </ul>		1,000,000 With 0.3 x I <sub>e</sub>
<b>T1 value / for proof test interval or service life / according to IEC 61508</b>	a	20

**Further information:**

**Information- and Downloadcenter (Catalogs, Brochures,...)**

<http://www.siemens.com/industrial-controls/catalogs>

**Industry Mall (Online ordering system)**

<http://www.siemens.com/industrial-controls/mall>

**Cax online generator**

<http://www.siemens.com/cax>

**Service&Support (Manuals, Certificates, Characteristics, FAQs,...)**

<http://support.automation.siemens.com/WWW/view/en/3TH4262-0AM0/all>

**Image database (product images, 2D dimension drawings, 3D models, device circuit diagrams, ...)**

[http://www.automation.siemens.com/bilddb/cax\\_en.aspx?mlfb=3TH4262-0AM0](http://www.automation.siemens.com/bilddb/cax_en.aspx?mlfb=3TH4262-0AM0)

last change:

Jun 16, 2014