

## MI8A-I/O S SUBD15B

**Weidmüller Interface GmbH & Co. KG**  
Klingenbergstraße 26  
D-32758 Detmold  
Germany

[www.weidmueller.com](http://www.weidmueller.com)



Specific adapter to be connected to the MICROSERIE RELAYS using a 10-pole flat-cable connector or 15-pole Sub-D connector.

### General ordering data

Version	Adapter, MICRO-Interface, IEC 60603/DIN41612 plug-in connectors, Screw connection
Order No.	<a href="#">8800220000</a>
Type	MI8A-I/O S SUBD15B
GTIN (EAN)	4032248497157
Qty.	10 pc(s).

Creation date March 29, 2021 11:18:55 PM CEST

Catalogue status 12.03.2021 / We reserve the right to make technical changes.

## MI8A-I/O S SUBD15B

**Weidmüller Interface GmbH & Co. KG**  
 Klingenbergstraße 26  
 D-32758 Detmold  
 Germany

www.weidmueller.com

## Technical data

### Dimensions and weights

Height	42 mm	Height (inches)	1.654 inch
Length	32 mm	Length (inches)	1.26 inch
Net weight	31.8 g	Width	61 mm
Width (inches)	2.402 inch		

### Temperatures

Storage temperature	-20...85 °C	Operating temperature	0...50 °C
---------------------	-------------	-----------------------	-----------

### Environmental Product Compliance

REACH SVHC	Potassium perfluorobutane sulfonate 29420-49-3
------------	--

### Connection data

Voltage supply	max. 30 V AC/DC
----------------	-----------------

### Ratings data

Operating voltage	30 V UC	Max. current per channel	0.5 A
Total operating current	2 A		

### Insulation coordination (EN50178)

According to	DIN EN 50178	Rated insulation voltage	< 50 V AC
Surge voltage category	III	Pollution severity level	2
Insulation test voltage	0.35 kVAC		

### Supply connection

Type of connection	Screw connection
--------------------	------------------

### Classifications

ETIM 6.0	EC002584	ETIM 7.0	EC002584
ECLASS 9.0	27-33-02-92	ECLASS 9.1	27-24-22-92
ECLASS 10.0	27-33-02-92	ECLASS 11.0	27-33-02-92

### Approvals

Approvals



ROHS	Conform
------	---------

### Downloads

Engineering Data	<a href="#">EPLAN</a>
------------------	-----------------------

Creation date March 29, 2021 11:18:55 PM CEST

Catalogue status 12.03.2021 / We reserve the right to make technical changes.